

2430 "E" Street, N. W.
Washington, D. C.
13 October 1953

25X1A9a



STATSPEC

1. Trench Covers in [redacted]
2. Height of Light Switches

25X1A9a

Dear Mr. [redacted]:

Reference is made to your letter of 9 October 1953 concerning same subjects:

a. Concur in statement that trench and trench covers in [redacted] should conform with Detail "X" shown on Drawing No. 7-5. A contract change order will be issued on receipt of Contractor's proposal.

STATSPEC

b. There seems to be no good reason why switches are mounted 5'-0" above floor. Suggest that you have [redacted] check plans for furniture arrangement to see if there is any interference. It would be desirable to have switches lowered to 4'-0" above floor if there would be no additional cost to the Government.

25X1A

Very truly yours,



25X1A9a